

Date - 31-Mar-2022



## National Fire & Safety Solutions

Health, Security, Safety & Fire Equipments Sales, Services & Traning E- mail: nfsssales101@gmail.com

Off.: Indian Institute of Fire Engineering, Makardhokda, Katol Road, Nagpur - 13 26, Chaitaneshwar Nagar, Kharbi Road, Wathoda layout, Nagpur - 34

To M/s.

OM VIDYANIKETAN

Address: CBSC SCHOOL UMRED

Mobile 8208377470

## **CERTIFICATE**

## FOR TEST AND GUARANTEE

Certified that Dry Powder ABC Stored Pressure / Co2 Type Fire Extinguisher, Water Co2 Type Fire Extinguisher, AFFF mechanical foam fire Extinguisher.

Capacity 1Kg

2Kg

4.5Kg

5Kg

9Ltr

4Kg

6Kg

9Kg

They are hydraulically tested as follows:

Hydraulically Body tested to: 30 Kg f/cm2 -250Kg f/cm2

Performance test as per IS: 13849, IS: Carried out.

## **GUARANTEE**

The above mentioned goods are guaranteed against defect in material and workmanship under normal use. The guarantee in limited to a period of **01 Years from the of supply refilling.** The company obligation shall be limited to rectifying; repairing or replacing defective parts provided the Purchaser has given immediate written notice upon the discovery of such defects. The company will be automatically relived of its obligation in case the unit is opened or any charges / repairs of made without its prior.

Approval within the guarantee period. The parts which are defective and of excludes any and every other obligation for or damages direct of consequential of for any accident resulting from the defective faulty workmanship.

Refilling Date:

31-Mar-2022

Expiry Date:

30-Mar-2023

Place:

Nagpur

For. National Fire & Safety Solutions

**Authorized Signatury**